

CSIR-NORTH EAST INSTITUTE OF SCIENCE & TECHNOLOGY
(Council of scientific and industrial research)

NAME OF WORK : Supplying , installation , testing and commissioning of Auditorium Outdoor Panel at CSIR-NEIST, Jorhat

Sl No	Particulars of the item	Qty	Unit	Rate in figures in	Rate in words	Amount in Rs.
1	<p>Supplying, installation, testing and commissioning of outdoor panel , IP 54 degree of protection, system voltage 415V, 50 Hz. CPRI approved with ribbed type external surface, made of high quality GRP (Glass Fibre Reinforced Polyester, ie Polyester + Glass Fibre), characterised with resistance to atmospheric (UV), double insulated slow burning & self extinguishing, weather proof, rush proof, corrosion free in nature in accordance with IEC 60 695. Class-II, double insulated protection with resistance to chemical and certification in accordance with IEC 60 439-1, IEC 60 439-3, IEC 60 439-5 and EN 60 208. complete as directed and specified by department. Hensel or similar polycarbonate Make</p> <p>Size : (3705 x 1183 x 320)mm</p> <p>Incomer : 400A FP 50 kA MCCB - 02 Nos. L&T/ABB Make)</p> <p>Bus Coupler : 400A FP 50 kA MCCB - 01 No. L&T/ABB Make)</p> <p>Outgoing : 350A FP 50 kA MCCB - 02 Nos. L&T/ABB Make) 250A FP 50 kA MCCB - 02 Nos. L&T/ABB Make) 125A FP 50 kA MCCB - 01 No. L&T/ABB Make) 63A FP 36 kA MCCB - 01 No. L&T/ABB Make)</p>	1	Each			
2	<p>Supplying, installation, testing and commissioning of modular/combinable polycarbonate insulated outdoor feeder pillar of IP 65 degree of protection, system voltage 415V, 50 Hz. with ASTA certification by CPRI and manufactures routine test certification, weather proof, rush proof, UV resistant, halogen free, silica free, corrosion proof, totally insulated having internal embedded gasket with provision for cable entry through gland , flame reterdant & self extinguishing in nature in accordance with IEC 60 695. Class-II, double insulated protection with resistance to chemical and mineral oil, EMC compliant Bus Bar system complete as directed and specified by department. Hensel or similar polycarbonate Make</p> <p>Size : (800 x 1050 x 375)mm</p> <p>I/C Cable - 1R x 3.5C x 95 Sq.mm-1 No</p> <p>O/G Cable -1R x 3.5C x 95 Sq.mm-1No</p>	1	Each			
3	Dismantling the existing panel board and stores to General Stores as specified and directed by deptt		LS			
Total quoted amount in Rs.						

Rupees :

Only

NB: Rate must be written both figures and words